SEW4_A	SWG	NVITL	2:35 PM 5/10/07	Alarm	N	#2 Treatment Plant Summary Alarm
PHASPB	FMEA	STAT	2:35 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	2:35 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
SEW4_A	SWG	NVITL	3:00 PM 5/10/07	Alarm	N	#2 Treatment Plant Summary Alarm
ALSPB	FMEA	STAT	3:00 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	3:00 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEW4_A	SWG	NVITL	3:21 PM 5/10/07	Alarm	N	#2 Treatment Plant Summary Alarm
PHASPB	FMEA	STAT	3:21 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED

05/10/07 CIMPLICITY ALARM LOG

ALSPB	FMEA	STAT	3:21 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
Alarmid	Resource	Class	Time	State	Ack	Alarm Message
SWBD016	GEN1	STAT	4:14 PM 5/10/07			Generator 1 Not in Auto
SEA11A	GEN1	STAT	4:15 PM 5/10/07			Dsl Gen 1 Cool Pump Running
SWBD066	GEN3	STAT	4:15 PM 5/10/07			Generator 3 Not in Auto
SEA31A	GEN3	STAT	4:16 PM 5/10/07			Dsl Gen 3 Cool Pump Running
SEA51A	SEA	STAT	4:32 PM 5/10/07			Z Drive Cool Pump #1 Running
SEA61A	SEA	STAT	4:32 PM 5/10/07			Z Drive Cool Pump #2 Running
SWBD017	GEN1	STAT	4:35 PM 5/10/07			Generator 1 CKT Bkr Closed
SWBD067	GEN3	STAT	4:36 PM 5/10/07			Generator 3 CKT Bkr Closed
FL41A	BLG	STAT	4:44 PM 5/10/07			F/O Pump #1 Run Status
FL41B	BLG	STAT	5:01 PM 5/10/07			F/O Pump #1 Stop Status
AC06	HELT	STAT	5:10 PM 5/10/07			Harm Filter Stbd Contactor Closed
PRP084_A	PRP	VITAL	5:17 PM 5/10/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	5:17 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	5:17 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB071A	BLG	STAT	5:52 PM 5/10/07			Port Fire Pump Running
BB071B	BLG	STAT	5:53 PM 5/10/07			Port Fire Pump Stopped
BB061A	BLG	STAT	5:53 PM 5/10/07			Fire/Bilge Pump #1 Running
SEW2_A	SWG	NVITL	6:12 PM 5/10/07	Alarm	N	#1 Treatment Plant Summary Alarm
ALSPB	FMEA	STAT	6:12 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	6:12 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEW2_A	SWG	NVITL	6:13 PM 5/10/07	Alarm	N	#1 Treatment Plant Summary Alarm
ALSPB	FMEA	STAT	6:14 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	6:14 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB071A	BLG	STAT	6:18 PM 5/10/07			Port Fire Pump Running
BB071B	BLG	STAT	6:19 PM 5/10/07			Port Fire Pump Stopped
SEW2_A	SWG	NVITL	6:29 PM 5/10/07	Alarm	N	#1 Treatment Plant Summary Alarm
ALSPB	FMEA	STAT	6:30 PM 5/10/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	6:30 PM 5/10/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB061B	BLG	STAT	6:40 PM 5/10/07			Fire/Bilge Pump #1 Stopped
BB061A	BLG	STAT	7:04 PM 5/10/07			Fire/Bilge Pump #1 Running
BB071A	BLG	STAT	7:05 PM 5/10/07			Port Fire Pump Running
BB071B	BLG	STAT	7:06 PM 5/10/07			Port Fire Pump Stopped
AC06	HFLT	STAT	7:43 PM 5/10/07			Harm Filter Stbd Contactor Closed
BB071A	BLG	STAT	7:47 PM 5/10/07			Port Fire Pump Running
BB061B	BLG	STAT	8:12 PM 5/10/07			Fire/Bilge Pump #1 Stopped
BB071B	BLG	STAT	8:12 PM 5/10/07			Port Fire Pump Stopped
FL41A	BLG	STAT	9:40 PM 5/10/07			F/O Pump #1 Run Status
FL41B	BLG	STAT	10:07 PM 5/10/07			F/O Pump #1 Stop Status

05/11/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
FL51A	BLG	STAT	7:13 AM 5/11/07			F/O Pump #2 Run Status
FL41A	BLG	STAT	7:13 AM 5/11/07			F/O Pump #1 Run Status
SWBD068	GEN3	STAT	7:35 AM 5/11/07			Generator 3 CKT Bkr Opened
ME3RUNI	GEN3	STAT	7:35 AM 5/11/07			Engine #3 Run Status
G3UF_A	GEN3	VITAL	7:35 AM 5/11/07	Alarm	N	Generator 3 Under Frequency
G3UV_A	GEN3	VITAL	7:35 AM 5/11/07	Alarm	N	Generator 3 Under Voltage
ALSPB	FMEA	STAT	7:35 AM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:35 AM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEW9_A	SWG	NVITL	7:39 AM 5/11/07	Alarm	N	Blackwater TLI
ALSPB	FMEA	STAT	7:39 AM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:39 AM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA31B	GEN3	STAT	7:41 AM 5/11/07			Dsl Gen 3 Cool Pump Stopped
GEN080	GEN3	STAT	7:41 AM 5/11/07			Dsl Gen 3 System Shutdown
FL41B	BLG	STAT	7:43 AM 5/11/07			F/O Pump #1 Stop Status
FL51B	BLG	STAT	7:43 AM 5/11/07			F/O Pump #2 Stop Status
SEA31A	GEN3	STAT	7:45 AM 5/11/07			Dsl Gen 3 Cool Pump Running
SWBD067	GEN3	STAT	7:48 AM 5/11/07			Generator 3 CKT Bkr Closed
AC06	HFLT	STAT	7:56 AM 5/11/07			Harm Filter Stbd Contactor Closed
PRP084_A	PRP	VITAL	7:59 AM 5/11/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	7:59 AM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	8:00 AM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD086	GEN4	STAT	8:37 AM 5/11/07			Generator 4 Not in Auto
ME4RUNI	GEN4	STAT	8:37 AM 5/11/07			Engine #4 Run Status
SEA41B	GEN4	STAT	8:43 AM 5/11/07			Dsl Gen 4 Cool Pump Stopped
GEN120	GEN4	STAT	8:43 AM 5/11/07			Dsl Gen 4 System Shutdown
BB061A	BLG	STAT	10:00 AM 5/11/07			Fire/Bilge Pump #1 Running
AC06	HFLT	STAT	10:08 AM 5/11/07			Harm Filter Stbd Contactor Closed
BB061B	BLG	STAT	10:36 AM 5/11/07			Fire/Bilge Pump #1 Stopped
AC06	HFLT	STAT	10:53 AM 5/11/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	12:36 PM 5/11/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	1:08 PM 5/11/07			Harm Filter Stbd Contactor Closed
SEW4_A	SWG	NVITL	1:56 PM 5/11/07	Alarm	N	#2 Treatment Plant Summary Alarm
ALSPB	FMEA	STAT	1:56 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	1:56 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEW9_A	SWG	NVITL	2:24 PM 5/11/07	Alarm	N	Blackwater TLI
PHASPB	FMEA	STAT	2:24 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	2:24 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
AC06	HFLT	STAT	3:58 PM 5/11/07			Harm Filter Stbd Contactor Closed
FL41A	BLG	STAT	4:02 PM 5/11/07			F/O Pump #1 Run Status
SEW9_A	SWG	NVITL	4:43 PM 5/11/07	Alarm	N	Blackwater TLI
PHASPB	FMEA	STAT	4:44 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:44 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
SEW9_A	SWG	NVITL	4:58 PM 5/11/07	Alarm	N	Blackwater TLI
PHASPB	FMEA	STAT	4:58 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:58 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
FL41B	BLG	STAT	5:00 PM 5/11/07			F/O Pump #1 Stop Status
SEW9_A	SWG	NVITL	5:43 PM 5/11/07	Alarm	N	Blackwater TLI

PHASPB	FMEA	STAT	5:10 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
AC06	HFLT	STAT	6:11 PM 5/11/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	6:41 PM 5/11/07			Harm Filter Stbd Contactor Closed
PRP084_A	PRP	VITAL	7:12 PM 5/11/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	7:12 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:12 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
AC06	HFLT	STAT	7:13 PM 5/11/07			Harm Filter Stbd Contactor Closed
FL41A	BLG	STAT	8:56 PM 5/11/07			F/O Pump #1 Run Status

05/11/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
FL41B	BLG	STAT	9:26 PM 5/11/07			F/O Pump #1 Stop Status
ALSPB	FMEA	STAT	9:37 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PRP084_A	PRP	VITAL	9:37 PM 5/11/07	Alarm	N	Hydraulic Pump Off, Jet Pump
PHASPB	FMEA	STAT	9:37 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD068	GEN3	STAT	9:38 PM 5/11/07			Generator 3 CKT Bkr Opened
ME3RUNI	GEN3	STAT	9:38 PM 5/11/07			Engine #3 Run Status
G3UF_A	GEN3	VITAL	9:38 PM 5/11/07	Alarm	N	Generator 3 Under Frequency
ALSPB	FMEA	STAT	9:38 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
G3UV_A	GEN3	VITAL	9:38 PM 5/11/07	Alarm	N	Generator 3 Under Voltage
PHASPB	FMEA	STAT	9:38 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
JDBKROP_A	JPD	VITAL	9:38 PM 5/11/07	Alarm	N	Jet Drive Breaker Open
ZSBKROP_A	SZD	VITAL	9:38 PM 5/11/07	Alarm	N	Stbd Z-Drive Breaker Open
ALSPB	FMEA	STAT	9:38 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	9:38 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ZPBKROP_A	PZD	VITAL	9:38 PM 5/11/07	Alarm	N	Port Z-Drive Breaker Open
ALSPB	FMEA	STAT	9:38 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	9:38 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
PRP006_A	PRP	VITAL	9:39 PM 5/11/07	Alarm	N	Hydraulic Pump Off, Z-Drive Port
SEA61B	SEA	STAT	9:39 PM 5/11/07			Z Drive Cool Pump #2 Stopped
PRP045_A	PRP	VITAL	9:39 PM 5/11/07	Alarm	N	Hydraulic Pump Off, Z-Drive Stbd
SEA51B	SEA	STAT	9:39 PM 5/11/07			Z Drive Cool Pump #1 Stopped
ALSPB	FMEA	STAT	9:39 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	9:39 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA31B	GEN3	STAT	9:43 PM 5/11/07			Dsl Gen 3 Cool Pump Stopped
GEN080	GEN3	STAT	9:43 PM 5/11/07			Dsl Gen 3 System Shutdown
SWBD018	GEN1	STAT	9:48 PM 5/11/07			Generator 1 CKT Bkr Opened
ME1RUNI	GEN1	STAT	9:48 PM 5/11/07			Engine #1 Run Status
G1UF_A	GEN1	VITAL	9:48 PM 5/11/07	Alarm	N	Generator 1 Under Frequency
ALSPB	FMEA	STAT	9:48 PM 5/11/07			EOS ALARM SILENCE BUTTON PRESSED
G1UV_A	GEN1	VITAL	9:48 PM 5/11/07	Alarm	N	Generator 1 Under Voltage
PHASPB	FMEA	STAT	9:49 PM 5/11/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA11B	GEN1	STAT	9:54 PM 5/11/07			Dsl Gen 1 Cool Pump Stopped
GEN001	GEN1	STAT	9:54 PM 5/11/07			Dsl Gen 1 System Shutdown

05/12/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
HMI2LNA_A	AMS	VITAL	6:33 AM 5/12/07	Alarm	N	HMI Backup Ethernet LAN A Failed
HMI2LNB_A	AMS	VITAL	6:33 AM 5/12/07	Alarm	N	HMI Backup Ethernet LAN B Failed
ALSPB	FMEA	STAT	6:33 AM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	6:33 AM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD016	GEN1	STAT	10:27 AM 5/12/07			Generator 1 Not in Auto
HVAC40_A	HVAC	NVITL	12:03 PM 5/12/07	Alarm	N	AHU #2 Summary Failure
PHASPB	FMEA	STAT	12:04 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	12:04 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
SWBD016	GEN1	STAT	3:39 PM 5/12/07			Generator 1 Not in Auto
SEA11A	GEN1	STAT	3:39 PM 5/12/07			Dsl Gen 1 Cool Pump Running
SWBD066	GEN3	STAT	3:41 PM 5/12/07			Generator 3 Not in Auto
SEA31A	GEN3	STAT	3:41 PM 5/12/07			Dsl Gen 3 Cool Pump Running
GEN093_A	GEN3	NVITL	3:41 PM 5/12/07	Alarm	N	Dsl Gen 3 Fuel Pressure
ALSPB	FMEA	STAT	3:41 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	3:41 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD067	GEN3	STAT	4:16 PM 5/12/07			Generator 3 CKT Bkr Closed
SWBD068	GEN3	STAT	4:18 PM 5/12/07			Generator 3 CKT Bkr Opened
ME3RUNI	GEN3	STAT	4:18 PM 5/12/07			Engine #3 Run Status
G3UF_A	GEN3	VITAL	4:18 PM 5/12/07	Alarm	N	Generator 3 Under Frequency
G3UV_A	GEN3	VITAL	4:18 PM 5/12/07	Alarm	N	Generator 3 Under Voltage
ALSPB	FMEA	STAT	4:19 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	4:19 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
G2REVP_A	GEN2	VITAL	4:20 PM 5/12/07	Alarm	N	Gen 2 Reverse Power
SWBD017	GEN1	STAT	4:20 PM 5/12/07			Generator 1 CKT Bkr Closed
SWBD046	GEN2	STAT	4:20 PM 5/12/07			Generator 2 CKT Bkr Opened
ALSPB	FMEA	STAT	4:20 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	4:20 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD046	GEN2	STAT	4:21 PM 5/12/07			Generator 2 Not in Auto
G2REVP_A	GEN2	VITAL	4:22 PM 5/12/07	Alarm	N	Gen 2 Reverse Power
PHASPB	FMEA	STAT	4:22 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:22 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
SWBD047	GEN2	STAT	4:23 PM 5/12/07			Generator 2 CKT Bkr Closed
SEA318	GEN3	STAT	4:24 PM 5/12/07			Dsl Gen 3 Cool Pump Stopped
GEN080	GEN3	STAT	4:24 PM 5/12/07			Dsl Gen 3 System Shutdown
SWBD018	GEN1	STAT	4:24 PM 5/12/07			Generator 1 CKT Bkr Opened
ME1RUNI	GEN1	STAT	4:24 PM 5/12/07			Engine #1 Run Status
G1UF_A	GEN1	VITAL	4:24 PM 5/12/07	Alarm	N	Generator 1 Under Frequency
G1UV_A	GEN1	VITAL	4:24 PM 5/12/07	Alarm	N	Generator 1 Under Voltage
ALSPB	FMEA	STAT	4:24 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	4:24 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA11B	GEN1	STAT	4:29 PM 5/12/07			Dsl Gen 1 Cool Pump Stopped
GEN001	GEN1	STAT	4:29 PM 5/12/07			Dsl Gen 1 System Shutdown
PHASPB	FMEA	STAT	4:31 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	4:32 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD016	GEN1	STAT	4:41 PM 5/12/07			Generator 1 Not in Auto
SEA11A	GEN1	STAT	4:43 PM 5/12/07			Dsl Gen 1 Cool Pump Running
SWBD066	GEN3	STAT	4:43 PM 5/12/07			Generator 3 Not in Auto

SWBD067	GEN3	STAT	4:46 PM	5/12/07			Generator 3 CKT Bkr Closed
SEA51A	SEA	STAT	4:47 PM	5/12/07			Z Drive Cool Pump #1 Running
SEA61A	SEA	STAT	4:47 PM	5/12/07			Z Drive Cool Pump #2 Running
CB061A	BLG	STAT	5:02 PM	5/12/07			Fire/Bilge Pump #1 Running
BBOZZ_A	BLG	VITAL	5:02 PM	5/12/07	Alarm	N	Fire Main Pressure
PHASPB	FMEA	STAT	5:02 PM	5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	5:02 PM	5/12/07			EOS ALARM SILENCE BUTTON PRESSED

Alarmed Resource Class Time State Ack Alarm Message

BB061B	BLG	STAT	5:22 PM 5/12/07			Fire/Bilge Pump #1 Stopped
AC06	HFLT	STAT	6:03 PM 5/12/07			Harm Filter Stbd Contactor Closed
PRP034_A	PRP	VITAL	6:21 PM 5/12/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	6:21 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	6:21 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SWBD068	GEN3	STAT	7:48 PM 5/12/07			Generator 3 CKT Bkr Opened
ME3RUNI	GEN3	STAT	7:48 PM 5/12/07			Engine #3 Run Status
G3UF_A	GEN3	VITAL	7:48 PM 5/12/07	Alarm	N	Generator 3 Under Frequency
G3UV_A	GEN3	VITAL	7:48 PM 5/12/07	Alarm	N	Generator 3 Under Voltage
ALSPB	FMEA	STAT	7:48 PM 5/12/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:48 PM 5/12/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA31B	GEN3	STAT	7:54 PM 5/12/07			Dsl Gen 3 Cool Pump Stopped
GEN080	GEN3	STAT	7:54 PM 5/12/07			Dsl Gen 3 System Shutdown
AC06	HFLT	STAT	8:13 PM 5/12/07			Harm Filter Stbd Contactor Closed
SWBD066	GEN3	STAT	9:40 PM 5/12/07			Generator 3 Not in Auto
SEA31A	GEN3	STAT	9:41 PM 5/12/07			Dsl Gen 3 Cool Pump Running
SWBD067	GEN3	STAT	9:44 PM 5/12/07			Generator 3 CKT Bkr Closed
FL41A	BLG	STAT	10:20 PM 5/12/07			F/O Pump #1 Run Status
FL51A	BLG	STAT	10:20 PM 5/12/07			F/O Pump #2 Run Status
FL41B	BLG	STAT	10:43 PM 5/12/07			F/O Pump #1 Stop Status
FL51B	BLG	STAT	10:43 PM 5/12/07			F/O Pump #2 Stop Status
AC06	HFLT	STAT	11:28 PM 5/12/07			Harm Filter Stbd Contactor Closed
SWBD086	GEN4	STAT	11:46 PM 5/12/07			Generator 4 Not in Auto

05/13/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
SWBD068	GEN3	STAT	4:30 AM 5/13/07			Generator 3 CKT Bkr Opened
ME3RUNI	GEN3	STAT	4:30 AM 5/13/07			Engine #3 Run Status
G3UF_A	GEN3	VITAL	4:30 AM 5/13/07	Alarm	N	Generator 3 Under Frequency
G3UV_A	GEN3	VITAL	4:31 AM 5/13/07	Alarm	N	Generator 3 Under Voltage
ALSPB	FMEA	STAT	4:31 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	4:31 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA31B	GEN3	STAT	4:36 AM 5/13/07			Dsl Gen 3 Cool Pump Stopped
GEN080	GEN3	STAT	4:36 AM 5/13/07			Dsl Gen 3 System Shutdown
AC06	HFLT	STAT	5:01 AM 5/13/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	6:40 AM 5/13/07			Harm Filter Stbd Contactor Closed
HMI2LNA_A	AMS	VITAL	6:57 AM 5/13/07	Alarm	N	HMI Backup Ethernet LAN A Failed
PBWASPB	FMEA	STAT	6:57 AM 5/13/07			PORT BRIDGE WING ALARM SILENCE PRESSED
ALSPB	FMEA	STAT	6:57 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
HMI2LNB_A	AMS	VITAL	6:57 AM 5/13/07	Alarm	N	HMI Backup Ethernet LAN B Failed
PBWASPB	FMEA	STAT	6:57 AM 5/13/07			PORT BRIDGE WING ALARM SILENCE PRESSED
ALSPB	FMEA	STAT	7:09 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:09 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
PRP084_A	PRP	VITAL	7:10 AM 5/13/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	7:10 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:10 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
JDBKROP_A	JPD	VITAL	7:10 AM 5/13/07	Alarm	N	Jet Drive Breaker Open
PHASPB	FMEA	STAT	7:10 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTION PRESSED
ALSPB	FMEA	STAT	7:10 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
ZSBKROP_A	SZD	VITAL	7:10 AM 5/13/07	Alarm	N	Stbd Z-Drive Breaker Open
ALSPB	FMEA	STAT	7:10 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
ZPBKROP_A	PZD	VITAL	7:10 AM 5/13/07	Alarm	N	Port Z-Drive Breaker Open
SEA51B	SEA	STAT	7:11 AM 5/13/07			Z Drive Cool Pump #1 Stopped
PRP045_A	PRP	VITAL	7:11 AM 5/13/07	Alarm	N	Hydraulic Pump Off, Z-Drive Stbd
ALSPB	FMEA	STAT	7:11 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
SEA61B	SEA	STAT	7:11 AM 5/13/07			Z Drive Cool Pump #2 Stopped
PRP006_A	PRP	VITAL	7:11 AM 5/13/07	Alarm	N	Hydraulic Pump Off, Z-Drive Port
PRP053_A	PRP	VITAL	7:14 AM 5/13/07	Alarm	N	Normal Control Power Failure, Z-Drive Stbd
PHASPB	FMEA	STAT	7:14 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	7:14 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
PRP014_A	PRP	VITAL	7:15 AM 5/13/07	Alarm	N	Normal Control Power Failure, Z-Drive Port
ALSPB	FMEA	STAT	7:15 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:15 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED

METRUN1	GEN1	STAT	7:20 AM 5/13/07			Engine #1 Run Status
G1UF_A	GEN1	VITAL	7:20 AM 5/13/07	Alarm	N	Generator 1 Under Frequency
ALSPB	FMEA	STAT	7:20 AM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
G1UV_A	GEN1	VITAL	7:20 AM 5/13/07	Alarm	N	Generator 1 Under Voltage
PHASPB	FMEA	STAT	7:20 AM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEA11B	GEN1	STAT	7:26 AM 5/13/07			Dsl Gen 1 Cool Pump Stopped
GEN001	GEN1	STAT	7:26 AM 5/13/07			Dsl Gen 1 System Shutdown
FL41A	BLG	STAT	10:53 AM 5/13/07			F/O Pump #1 Run Status
FL51A	BLG	STAT	10:53 AM 5/13/07			F/O Pump #2 Run Status
FL41B	BLG	STAT	11:25 AM 5/13/07			F/O Pump #1 Stop Status
FL51B	BLG	STAT	11:25 AM 5/13/07			F/O Pump #2 Stop Status
SWBD066	GEN3	STAT	4:07 PM 5/13/07			Generator 3 Not in Auto
SWBD016	GEN1	STAT	4:07 PM 5/13/07			Generator 1 Not in Auto
SEA31A	GEN3	STAT	4:07 PM 5/13/07			Dsl Gen 3 Cool Pump Running
SEA11A	GEN1	STAT	4:07 PM 5/13/07			Dsl Gen 1 Cool Pump Running
SWBD017	GEN1	STAT	4:24 PM 5/13/07			Generator 1 CKT Bkr Closed
SWBD067	GEN3	STAT	4:25 PM 5/13/07			Generator 3 CKT Bkr Closed
SEA51A	SEA	STAT	4:27 PM 5/13/07			Z Drive Cool Pump #1 Running

05/13/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
SEA61A	SEA	STAT	4:27 PM 5/13/07			Z Drive Cool Pump #2 Running
AC06	HFLT	STAT	5:23 PM 5/13/07			Harm Filter Stbd Contactor Closed
PRP084_A	PRP	VITAL	5:24 PM 5/13/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	5:24 PM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	5:24 PM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
HMI2LNA_A	AMS	VITAL	5:33 PM 5/13/07	Alarm	N	HMI Backup Ethernet LAN A Failed
PHASPB	FMEA	STAT	5:33 PM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	5:33 PM 5/13/07			EOS ALARM SILENCE BUTTON PRESSED
HMI2LNB_A	AMS	VITAL	5:33 PM 5/13/07	Alarm	N	HMI Backup Ethernet LAN B Failed
PHASPB	FMEA	STAT	5:33 PM 5/13/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
AC06	HFLT	STAT	7:54 PM 5/13/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	8:28 PM 5/13/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	9:04 PM 5/13/07			Harm Filter Stbd Contactor Closed
AC06	HFLT	STAT	9:18 PM 5/13/07			Harm Filter Stbd Contactor Closed
FL51A	BLG	STAT	10:22 PM 5/13/07			F/O Pump #2 Run Status
FL41A	BLG	STAT	10:22 PM 5/13/07			F/O Pump #1 Run Status
FL41B	BLG	STAT	10:33 PM 5/13/07			F/O Pump #1 Stop Status
FL51B	BLG	STAT	10:33 PM 5/13/07			F/O Pump #2 Stop Status

5/13
22 33

05/14/07 CIMPLICITY ALARM LOG

5/14 0128

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
BB022_A	BLG	VITAL	1:28 AM 5/14/07	Alarm	N	Bilge Sensor, Chain Locker
BB009_A	BLG	VITAL	1:28 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 37-53 Port
BB023_A	BLG	VITAL	1:28 AM 5/14/07	Alarm	N	Bilge Sensor, Forepeak
FL1_A	BLG	NVITL	1:28 AM 5/14/07	Alarm	N	F/O Strg Tank Level, Port
ALSPB	FMEA	STAT	1:28 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PRP042_A	PRP	VITAL	1:28 AM 5/14/07	Alarm	N	Hyd Oil Boost Press Min, Z-Drive Stbd
DR1FB36_A	SZD	VITAL	1:28 AM 5/14/07	Alarm	N	Z-Stbd LFBVAR3 Armature Volts
PRP049_A	PRP	VITAL	1:28 AM 5/14/07	Alarm	N	Lube Oil Low Flow, Z-Drive Stbd
ALSPB	FMEA	STAT	1:28 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
BB011_A	BLG	VITAL	1:29 AM 5/14/07	Alarm	N	Bilge Sensor, Void #1
ALSPB	FMEA	STAT	1:29 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
BB013_A	BLG	VITAL	1:29 AM 5/14/07	Alarm	N	Bilge Sensor, Void #3
ALSPB	FMEA	STAT	1:30 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
ENGCPB_A	AMS	NVITL	1:30 AM 5/14/07	Alarm	N	Engineer Assistance Needed
FL7_A	BLG	NVITL	1:31 AM 5/14/07	Alarm	N	F/O Strg Tank Level, Center
BB012_A	BLG	VITAL	1:33 AM 5/14/07	Alarm	N	Bilge Sensor, Void #2
PHASPB	FMEA	STAT	1:33 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	1:33 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
BB071A	BLG	STAT	1:36 AM 5/14/07			Port Fire Pump Running
BV034	BLG	STAT	1:44 AM 5/14/07			Blg/Ballast Manifold Suct Blg Pmp2 Valve Clsd
FL22_A	BLG	NVITL	2:04 AM 5/14/07	Alarm	N	F/O Day Tank Level, Stbd
ALSPB	FMEA	STAT	2:05 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	2:05 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEW1_A	SWG	NVITL	2:10 AM 5/14/07	Alarm	N	Blackwater TLI
PHASPB	FMEA	STAT	2:10 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	2:13 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED

PHASPB	FMEA	STAT	2:18 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	2:18 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
FL4_A	BLG	NVITL	2:20 AM	5/14/07	Alarm	N	F/O Strg Tank Level, Stbd
PHASPB	FMEA	STAT	2:20 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	2:20 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
SEW9_A	SWG	NVITL	2:25 AM	5/14/07	Alarm	N	Blackwater TLI
ALSPB	FMEA	STAT	2:25 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	2:25 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB014_A	BLG	VITAL	3:15 AM	5/14/07	Alarm	N	Bilge Sensor, Void #4
PHASPB	FMEA	STAT	3:15 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	3:15 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PW7_A	POTW	NVITL	3:24 AM	5/14/07	Alarm	N	Potable Water Pressure
ALSPB	FMEA	STAT	3:24 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	3:24 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB014_A	BLG	VITAL	3:52 AM	5/14/07	Alarm	N	Bilge Sensor, Void #4
ALSPB	FMEA	STAT	3:52 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	3:52 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BV043	BLG	STAT	4:07 AM	5/14/07			JP Fire/Bilge Pump 1 Overbd Disch Valve Open
BV010	BLG	STAT	4:08 AM	5/14/07			JP Rm Fire/Bile Pump1 Fire Main Valve Clsd
BV007	BLG	STAT	4:09 AM	5/14/07			JP Rm Fire/Bilge Pmp 1 Suct Strain Valve Open
BB005_A	BLG	VITAL	4:12 AM	5/14/07	Alarm	N	Bilge Sensor, Frame 53-73 Port
PHASPB	FMEA	STAT	4:12 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:12 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
BB061A	BLG	STAT	4:16 AM	5/14/07			Fire/Bilge Pump #1 Running
BV002	BLG	STAT	4:17 AM	5/14/07			JP Rm Fire/Bilge Pmp 1 Seawater Suct Valve Clsd
BV003	BLG	STAT	4:17 AM	5/14/07			JP Rm Fire/Bilge Pmp 1 Seawater Suct Valve Open
PHASPB	FMEA	STAT	4:19 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BV002	BLG	STAT	4:22 AM	5/14/07			JP Rm Fire/Bilge Pmp 1 Seawater Suct Valve Clsd
BV003	BLG	STAT	4:24 AM	5/14/07			JP Rm Fire/Bilge Pmp 1 Seawater Suct Valve Open

05/14/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time		State	Ack	Alarm Message
BB004_A	BLG	VITAL	4:30 AM	5/14/07	Alarm	N	Bilge Sensor, Frame 89-109 Port
PHASPB	FMEA	STAT	4:30 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:30 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
BB005_A	BLG	VITAL	4:42 AM	5/14/07	Alarm	N	Bilge Sensor, Frame 53-73 Port
PHASPB	FMEA	STAT	4:42 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:42 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
SWBD068	GEN3	STAT	4:46 AM	5/14/07			Generator 3 CKT Bkr Opened
ME3RUNI	GEN3	STAT	4:46 AM	5/14/07			Engine #3 Run Status
G3UF_A	GEN3	VITAL	4:46 AM	5/14/07	Alarm	N	Generator 3 Under Frequency
G3UV_A	GEN3	VITAL	4:46 AM	5/14/07	Alarm	N	Generator 3 Under Voltage
PHASPB	FMEA	STAT	4:47 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	4:47 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
SWBD016	GEN1	STAT	4:47 AM	5/14/07			Generator 1 Not in Auto
SEA31B	GEN3	STAT	4:52 AM	5/14/07			Dsl Gen 3 Cool Pump Stopped
GEN080	GEN3	STAT	4:52 AM	5/14/07			Dsl Gen 3 System Shutdown
PWRA17_A	FMEA	VITAL	5:08 AM	5/14/07	Alarm	N	RDU7 Fuse F1A Fail
ALSPB	FMEA	STAT	5:08 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	5:08 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB013_A	BLG	VITAL	5:11 AM	5/14/07	Alarm	N	Bilge Sensor, Void #3
ALSPB	FMEA	STAT	5:11 AM	5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	5:11 AM	5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
B7A308F_A	FMEA	VITAL	5:13 AM	5/14/07	Alarm	N	BLOCK A07-A308 FAIL
B7A309F_A	FMEA	VITAL	5:13 AM	5/14/07	Alarm	N	BLOCK A07-A309 FAIL
B7A310F_A	FMEA	VITAL	5:13 AM	5/14/07	Alarm	N	BLOCK A07-A310 FAIL
B7D111F_A	FMEA	VITAL	5:13 AM	5/14/07	Alarm	N	BLOCK A07-D111 FAIL
B7D112F_A	FMEA	VITAL	5:13 AM	5/14/07	Alarm	N	BLOCK A07-D112 FAIL

B7R314F_A	FMEA	VITAL	5:13 AM 5/14/07	Alarm	N	BLOCK A07-R314 FAIL
FL11_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Fuel Oil Overflow Tank Level
FL10_A	BLG	NVITL	5:13 AM 5/14/07	Alarm	N	F/O Strg Tank Overflow Alarm
BB002_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 109-129 Port
BB004_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 89-109 Port
BB006_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 73-89 Port
BB012_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Void #2
BB014_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Void #4
BB010_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 37-53 Stbd
BB015_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 73-89 Stbd
BB018_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 89-109 Stbd
BB019_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 109-129 Stbd
BB009_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 37-53 Port
BB007_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 22-37 Port
BB008_A	BLG	VITAL	5:13 AM 5/14/07	Alarm	N	Bilge Sensor, Frame 22-37 Stbd
PFEAP1_A	AMS	VITAL	5:13 AM 5/14/07	Alarm	N	PF EAP Power Failure Sewage Equipment Rm
OLEAP1_A	AMS	VITAL	5:13 AM 5/14/07	Alarm	N	OL EAP Power Failure Crew Lounge
CEEAP1_A	AMS	VITAL	5:13 AM 5/14/07	Alarm	N	CE EAP Power Failure Engineer's Room
HVAC90_A	HVAC	NVITL	5:13 AM 5/14/07	Alarm	N	AHU #7 Summary Failure
HVAC100_A	HVAC	NVITL	5:13 AM 5/14/07	Alarm	N	AHU #8 Summary Failure
HVAC110_A	HVAC	NVITL	5:13 AM 5/14/07	Alarm	N	AHU #9 Summary Failure
SEW8_A	SWG	NVITL	5:13 AM 5/14/07	Alarm	N	Vacuum System Summary Alarm
AC20_A	PWR	NVITL	5:13 AM 5/14/07	Alarm	N	SS Transformer Port Hi Temp
AC21_A	PWR	VITAL	5:13 AM 5/14/07	Alarm	N	SS Transformer Port Hi-Hi Temp
AC23_A	PWR	NVITL	5:13 AM 5/14/07	Alarm	N	SS Transformer Stbd Hi Temp
AC24_A	PWR	VITAL	5:13 AM 5/14/07	Alarm	N	SS Transformer Stbd Hi-Hi Temp
AC31_A	PWR	NVITL	5:13 AM 5/14/07	Alarm	N	Ship's Service UPS Fail
F3_A	FIRE	VITAL	5:13 AM 5/14/07	Alarm	N	Sprinkler Tank Level Low
F5_A	FIRE	VITAL	5:13 AM 5/14/07	Alarm	N	Sprinkler Tank Pressure Low

05/14/07 CIMPLICITY ALARM LOG

Alarmid	Resource	Class	Time	State	Ack	Alarm Message
RF01_A	RFR	NVITL	5:13 AM 5/14/07	Alarm	N	Refer Hi Temperature Alarm
RF02_A	RFR	NVITL	5:13 AM 5/14/07	Alarm	N	Freezer Hi Temperature Alarm
PWRA18_A	FMEA	VITAL	5:13 AM 5/14/07	Alarm	N	RDU7 Fuse F18 Fail
AC26_A	PWR	NVITL	5:13 AM 5/14/07	Alarm	N	SS Transformer Port Temp 2
AC27_A	PWR	NVITL	5:13 AM 5/14/07	Alarm	N	SS Transformer Port Temp 3
PHASPB	FMEA	STAT	5:13 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
PW7_A	POTW	NVITL	5:13 AM 5/14/07	Alarm	N	Potable Water Pressure
PHASPB	FMEA	STAT	5:13 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
FL4_A	BLG	NVITL	5:13 AM 5/14/07	Alarm	N	F/O Strg Tank Level, Stbd
AC22_A	PWR	NVITL	5:13 AM 5/14/07	Alarm	N	SS Transformer Port Temp 1
ALSPB	FMEA	STAT	5:13 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	5:14 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
SEW9_A	SWG	NVITL	5:14 AM 5/14/07	Alarm	N	Blackwater TLI
ALSPB	FMEA	STAT	5:14 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	5:14 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
HMI2LNA_A	AMS	VITAL	5:33 AM 5/14/07	Alarm	N	HMI Backup Ethernet LAN A Failed
PHASPB	FMEA	STAT	5:33 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	5:33 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
HMI2LNB_A	AMS	VITAL	5:33 AM 5/14/07	Alarm	N	HMI Backup Ethernet LAN B Failed
PHASPB	FMEA	STAT	5:33 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	5:33 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
AC06	HFLT	STAT	6:44 AM 5/14/07			Harm Filter Stbd Contactor Closed
BB061B	BLG	STAT	6:45 AM 5/14/07			Fire/Bilge Pump #1 Stopped
PRP043_A	PRP	VITAL	7:02 AM 5/14/07	Alarm	N	Hydraulic Pump Off, Z-Drive Stbd
SEA13	SEA	STAT	7:02 AM 5/14/07			Z Drive Cool Pump #1 Stopped
ALSPB	FMEA	STAT	7:07 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED

SEA51A	SEA	STAT	7:07 AM 5/14/07			Z Drive Cool Pump #1 Running
SEA51B	SEA	STAT	7:07 AM 5/14/07			Z Drive Cool Pump #1 Stopped
PRP045_A	PRP	VITAL	7:08 AM 5/14/07	Alarm	N	Hydraulic Pump Off, Z-Drive Stbd
ALSPB	FMEA	STAT	7:08 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	7:08 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
BB061A	BLG	STAT	7:35 AM 5/14/07			Fire/Bilge Pump #1 Running
SEA51A	SEA	STAT	7:38 AM 5/14/07			Z Drive Cool Pump #1 Running
HMI2LNA_A	AMS	VITAL	8:09 AM 5/14/07	Alarm	N	HMI Backup Ethernet LAN A Failed
ALSPB	FMEA	STAT	8:09 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	8:09 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
HMI2LNB_A	AMS	VITAL	8:09 AM 5/14/07	Alarm	N	HMI Backup Ethernet LAN B Failed
PRP084_A	PRP	VITAL	10:41 AM 5/14/07	Alarm	N	Hydraulic Pump Off, Jet Pump
ALSPB	FMEA	STAT	10:41 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	10:41 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
JDBKROP_A	JPD	VITAL	10:41 AM 5/14/07	Alarm	N	Jet Drive Breaker Open
ALSPB	FMEA	STAT	10:41 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
PHASPB	FMEA	STAT	10:42 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ALSPB	FMEA	STAT	10:42 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED
ZPBKROP_A	PZD	VITAL	10:42 AM 5/14/07	Alarm	N	Port Z-Drive Breaker Open
PHASPB	FMEA	STAT	10:42 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
PRP045_A	PRP	VITAL	10:42 AM 5/14/07	Alarm	N	Hydraulic Pump Off, Z-Drive Stbd
SEA51B	SEA	STAT	10:42 AM 5/14/07			Z Drive Cool Pump #1 Stopped
PRP006_A	PRP	VITAL	10:42 AM 5/14/07	Alarm	N	Hydraulic Pump Off, Z-Drive Port
SEA61B	SEA	STAT	10:42 AM 5/14/07			Z Drive Cool Pump #2 Stopped
PHASPB	FMEA	STAT	10:42 AM 5/14/07			PILOT HOUSE ALARM SILENCE BUTTON PRESSED
ZSBKROP_A	SZD	VITAL	10:42 AM 5/14/07	Alarm	N	Stbd Z-Drive Breaker Open
SWBD01B	GEN1	STAT	10:42 AM 5/14/07			Generator 1 CKT Bkr Opened
ME1RUNI	GEN1	STAT	10:42 AM 5/14/07			Engine #1 Run Status
ALSPB	FMEA	STAT	10:43 AM 5/14/07			EOS ALARM SILENCE BUTTON PRESSED

5/14/07 G 1043 AM